

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (7.3E-01)	ND (8.0E-01)	Treated water tank	Jul 7, 2014	3:40 PM
Cs-137	ND (7.9E-01)	ND (9.4E-01)			
Gross β	4.6E+00	5.0E+00			
Tritium	1.8E+02	1.3E+02	Receiving tank	Jul 3, 2014	1:50 PM
Notification density rate*	0.18	0.19			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.